

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-0078:202 Page 1 of 1

CATEGORY: Control Units (Household)

LISTEE: ADEMCO, 165 Eileen Way, Syosset NY 11791
Contact: *Harry Pashkoff (516) 921-6704 Fax (516) 364-6953

DESIGN: Models Safewatch Pro3000, Safewatch Pro 3000i, Safewatch Pro 3000EN, Security Manager 3000, Security Manager 3000i, Security Manager 3000EN, Entrepreneur 3000I, Entrepreneur 3000EN, *FA130CP, FA148CP, FA148CP-CN, FA168C, *FA168C-GP, *FA168CPS, FA168C-CN, *Vista-10P, Vista-15P, Vista-15PMT, *Vista-20PS, *Vista-20PBAY, Vista-20P and *300P1 combination household fire and burglary alarm control units. Model SAVS20P2 Sub-Assembly Circuit Board and Model RES-UL Household Enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC Primary, 16.5 VDC secondary

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. All units shall provide a 24 hour battery standby as required by code.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as a combination household fire and burglary alarm control unit for use with for use with separately listed compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: ***Fire Alarm Verification Feature*** (delay of fire alarm signal) shall NOT be used in California.

*Rev. 11-25-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **NOVEMBER 25, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager